



Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

Lot ID: 251204

Date Received : Jan 03, 2025

Date Reported : Jan 14, 2025

Report Number : 3207092-1

P/O :

Project Name :

Project Location :

Page 1 of 5

Sample Number 251204-1
 Sampled Date Jan 03, 2025
 Sample Description น้ำดื่มสปริงเคิล เดือนมกราคม 2568
 Date Analysis Commenced Jan 04, 2025
 Condition of Sample Contained in eighteen plastic bottles (client container)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Aluminium	mg/L	0.003	0.005	Not Detected	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Arsenic	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Barium	mg/L	0.0003	0.0005	Not Detected	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Cadmium	mg/L	0.0003	0.0005	Not Detected	≤0.003	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Chromium	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Copper	mg/L	0.0003	0.0005	Not Detected	≤1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Iron	mg/L	0.003	0.005	Not Detected	≤0.3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Lead	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Manganese	mg/L	0.0003	0.0005	Not Detected	≤0.05	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok

1117

15/01/2025

Approved by

Sawitree N.

Sawitree Noisangiam
Manager

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.



Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

Lot ID: 251204

Date Received : Jan 03, 2025

Date Reported : Jan 14, 2025

Report Number : 3207092-1

P/O :

Project Name :

Project Location :

Page 2 of 5

Sample Number 251204-1
 Sampled Date Jan 03, 2025
 Sample Description น้ำดื่มสปริงเคิล เดือนมกราคม 2568
 Date Analysis Commenced Jan 04, 2025
 Condition of Sample Contained in eighteen plastic bottles (client container)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Metals Testing							
Mercury	mg/L	0.0001	0.0005	Not Detected	≤0.001	In-house method : STM 05-007 based on United States Environmental Protection Agency, 2002, EPA Method 1631, Revision E	Bangkok
Selenium	mg/L	0.0003	0.0005	Not Detected	≤0.01	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Silver	mg/L	0.0003	0.0005	Not Detected	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Zinc	mg/L	0.003	0.005	Not Detected	≤3	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd Edition, 2017, part 3125	Bangkok
Microbiological Testing							
<i>Clostridium perfringens</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-012 in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9260 A,B - FDA BAM online, 2001 (Chapter 16)	Bangkok
<i>Escherichia coli</i>	in 100 mL	-	-	Not Detected	Not Detected	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 F	Bangkok
<i>Salmonella spp.</i>	in 100 mL	-	-	Not Detected	Not Detected	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 9260 B	Bangkok
Standard Plate Count	CFU/mL	-	-	<1	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, Part 9215 B	Bangkok

1179
15/01/2025
Approved by Sawitree N.
Sawitree Noisangiam
Manager

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.



Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

Lot ID: 251204

Date Received : Jan 03, 2025

Date Reported : Jan 14, 2025

Report Number : 3207092-1

P/O :

Project Name :

Project Location :

Page 3 of 5

Sample Number 251204-1
Sampled Date Jan 03, 2025
Sample Description น้ำดื่มสปริงเคิล เดือนมกราคม 2568
Date Analysis Commenced Jan 04, 2025
Condition of Sample Contained in eighteen plastic bottles (client container)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Microbiological Testing							
<i>Staphylococcus aureus</i>	in 100 mL	-	-	Not Detected	Not Detected	In-house method STM No. 01-054 in connection with: - Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9213 B - FDA BAM online, 2016 (Chapter 12)	Bangkok
Total Coliform	MPN/100mL	-	-	<1.1	<1.1	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 9221 B	Bangkok
Water Testing							
Alkylbenzene Sulfonate as MBAS	mg/L	0.05	0.1	Not Detected	≤0.2	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 5540 C	Bangkok
Bromate	mg/L	0.001	0.005	<0.005	No Standard	In-house method : STM 04-061 based on United States Environmental Protection Agency, 1999, EPA Method 300.1	Bangkok
Chloride as Cl	mg/L	0.06	0.2	1.5	≤250	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Color	Color unit	-	5	<5	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 2120 B	Bangkok
Cyanide as CN	mg/L	0.002	0.005	Not Detected	≤0.07	In-house method : STM 04-007 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500 - CN (C, E)	Bangkok
Fluoride as F	mg/L	0.05	0.1	Not Detected	≤0.7	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok

1179

15/01/2025

Approved by

Sawitree N.

Sawitree Noisangiam

Manager

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.



Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

P/O :
Project Name :
Project Location :

Lot ID: 251204

Date Received : Jan 03, 2025

Date Reported : Jan 14, 2025

Report Number : 3207092-1

Page 4 of 5

Sample Number 251204-1
Sampled Date Jan 03, 2025
Sample Description น้ำดื่มสปริงเคิล เดือนมกราคม 2568
Date Analysis Commenced Jan 04, 2025
Condition of Sample Contained in eighteen plastic bottles (client container)

Analyte	Unit	LOD	LOQ (LOR)	Result	Guideline / Specification	Method	Testing Location
Water Testing							
Nitrate as N	mg/L	0.06	0.2	Not Detected	≤4	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Odour		-	-	Odourless	Non Objectionable	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2150 B	Bangkok
pH at 25 degree C		-	-	7.0	6.5-8.5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4500 - H (B)	Bangkok
Phenol	mg/L	0.0005	0.001	Not Detected	≤0.001	In-house method : STM 04-022 based on Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 5530 C	Bangkok
Sulfate	mg/L	0.15	0.5	7.2	≤200	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 23rd ed., 2017, part 4110 B	Bangkok
Total Dissolved solids Dried at 180 degree C	mg/L	-	5	9	≤500	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2540 C	Bangkok
Total Hardness as CaCO ₃	mg/L	0.5	1	<1	≤100	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2340 C	Bangkok
Total Solids Dried at 103-105 degree C	mg/L	-	5	12	No Standard	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2540 B	Bangkok
Turbidity	NTU	-	0.1	0.20	≤5	Standard Methods for the Examination of Water and Wastewater. APHA, AWWA & WEF, 24th ed., 2023, part 2130 B	Bangkok

Guideline : Thai Industrial Standard No. 257-2549 refer to Notification of the Ministry of Industry No. 3470 (B.E. 2549).

1179

15/01/2025

Approved by

Sawitree N.

Sawitree Noisangiam
Manager

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER



Accreditation No. 1031/47

Analysis / Test Report

Client : M. Water Co., Ltd.
204 Moo 3, T.Chamaep, A.Wangnoi, Phranakorn Sri Ayutthaya 13170

P/O :

Project Name :

Project Location:

Lot ID: 251204

Date Received : Jan 03, 2025

Date Reported : Jan 14, 2025

Report Number : 3207092-1

Page 5 of 5

Remark :

- LOD : Limit of Detection
- "<" : Lower than LOQ (Limit of Quantitation) / LOR (Limit of Reporting)
- Analyte(s) marked * is/are not included in scope of Accreditation ISO/IEC 17025.
- The laboratory has been accepted as an accredited laboratory complying with the ISO/IEC 17025.

Handwritten signature

15 Jan 2025

Results apply to the sample(s) as submitted, unless the sampling was conducted by ALS. No part of this report may be reproduced in any form without written consent from the laboratory. ALS Laboratory Group (Thailand) strongly recommends that this report is not reproduced except in full.

Approved by

Sawitree N.

Sawitree Noisangiam

Manager

ADDRESS 104 Phatthanakan 40, Phatthanakan Rd., Khwaeng Phatthanakan, Khet Suan Luang, Bangkok 10250 Thailand | PHONE +66 0 2760 3000 | FAX +66 0 2760 3197
ALS LABORATORY GROUP (THAILAND) CO., LTD. An ALS Limited Company

Life Sciences

www.alsglobal.com

RIGHT SOLUTIONS RIGHT PARTNER